

**ADDENDUM NO. 4**

**DATE:** April 18, 2018  
**PROJECT:** Munising Public Schools Mather Elementary Renovation  
**OWNER:** Munising Public Schools  
**BID DATE:** Friday, April 20, 2018 at 10:00 a.m.

The following shall be incorporated into the Contract Documents dated **26 MAR 2018**.

**DRAWINGS**

---

**A-402 – ROOM SCHEDULE & TYPICAL DETAILS – NOT ISSUED**

Finish Legend: Add to the Finish Codes:

CWB-1; Ceramic Wall Base; Olympia Tile+Stone Colour & Dimension Style; Turquoise; Bright; 4.25"x6" size, cove base.

CWT-1; Ceramic Wall Tile; Olympia Tile+Stone Colour & Dimension Style; Turquoise; Bright; 4.25"x16" size.

**SECOND FLOOR ROOM FINISH SCHEDULE:**

Add notes to GIRL'S TOILET #1212: West wall at new lavatories to have CWB-1 AND CWT-1. Refer to interior elevation 4/A-113 at West Elevation, bubbled and tagged with revision #1.

**SECOND FLOOR ROOM FINISH SCHEDULE:**

Add notes to BOY'S TOILET #1244: East wall at new lavatories to have CWB-1 and CWT-1 (see sheet A-402 above). Refer to interior elevation 3/A-113 at East Elevation, bubbled and tagged with revision #1. South at new urinals to have CWB-1 and CWT-1 (see sheet A-402 above). Refer to interior elevation 3/A-113 at South Elevation, bubbled and tagged with revision #1.

**A-403 – SIGNAGE SCHEDULES AND DETAILS – NOT ISSUED**

Secondary signage lettering in the Admin Office area will be pin mounted cast metal letters in a Copperplate font, 10" high and 3/4" thick with a flat face. The color and finish will be selected at a later date once the interior colors are finalized. For further information, refer to Addendum #2, added information for sheet A-501, and Addendum #3 where this information is noted on the issued sheet A-501; detail 1/A501 Admin and Reception interior elevations, where the signage is bubbled and tagged with revision tag 2. Secondary signage lettering at the Classroom Entries will be bottom mounted cast metal letters in a Copperplate font, 8" high and 2" thick with a flat face. The color and finish will be selected at a later date once the interior colors are finalized. See Sheet A403 for further information.

**End of Addendum No. 4**