



ADDENDUM NO. 1

DATE: December 29, 2015

PROJECT: Marquette Area Public Schools – Natatorium Exterior Wall Improvements

OWNER: Marquette Area Public Schools

BID DATE: Wednesday, January 6, 2016 at 10:00 am

The following shall be incorporated into the Contract Documents dated **4 DEC 2015**.

GENERAL

The mandatory prebid meeting attendee list is attached.
Marquette County has reviewed the scope of work and indicated that plan review is not required.

PROJECT MANUAL

074213.13 Formed Metal Wall Panels:

Section 2.4.A.1 – Two coat fluoropolymer is acceptable.

DRAWINGS

Sheet 2-A1: Partial First Floor Plan:

Add note: Reinstall wall plates and bolts supporting dive boards. Adjust bolt length as required due to change in wall width.

End of Addendum No. 1

