



ADDENDUM NO. 1

DATE: April 11, 2018
PROJECT: Marquette School Steam System Upgrades
OWNER: Marquette Area Public Schools
BID DATE: Wednesday, April 18, 2018

The following shall be incorporated into the Contract Documents dated **19 MAR 2018**.

DRAWINGS

M-301 ENLARGED BOILER ROOM PLAN (NOT ISSUED)

Add the following Key Note.

E.1 – Work to include disconnect and reconnect of electrical circuits to pump motors and replacement of short circuit and overload protection (in existing starters) for pump motors as required for new pump sizes.

End of Addendum No. 1