



ADDENDUM NO. 2

DATE: September 18, 2018

PROJECT: City of Milan Utility Infrastructure Improvements and Extension

OWNER: City of Milan

BID DATE: Tuesday, September 25, 2018

The following shall be incorporated into the Contract Documents dated **8 August 2018**

This Addendum contains 2 pages.

PROJECT MANUAL

33 05 23.13 UTILITY HORIZONTAL DIRECTIONAL DRILLING

2.4.C.1. Sentence was replaced with the following text: "Pipe: Ductile Iron ANSI Thickness Class 54 for Water Mains and ANSI Thickness Class 52 for Sewage Force Mains."

ACKNOWLEDGEMENT of RECEIPT OF
REVISED ADDENDUM 1 And ADDENDUM 2

ATTENTION:

Please complete this form and return immediately by email to Trista.McLaughlin@ohm-advisors.com.

Our firm: _____

has received from Orchard, Hiltz, & McCliment, Inc.

Addendum No. 1 for: **City of Milan Utility Infrastructure Improvements
and Extension**

City of Milan

OHM Job No. 0185-17-0080

Today, _____ (date) at _____ (time) a.m. / p.m. (circle one)

Signature of receiver: _____

Printed name of receiver: _____

Company name: _____

End of Addendum No. 2