



ADDENDUM NO. 2

DATE: April 11, 2018
PROJECT: Marquette School Steam System Upgrades
OWNER: Marquette Area Public Schools
BID DATE: Wednesday, April 18, 2018

The following shall be incorporated into the Contract Documents dated **19 MAR 2018**.

GENERAL

Assume non-ACM material in your bid. The School District will remove any ACM prior to your contract starting if it identified in the sampling.

All steam traps are $\frac{3}{4}$ " F&T with a $\frac{3}{4}$ " inverted bucket trap.

Include the re-installation of the chemical feed injection pumps into a new line if the extent of the demolition includes removal of the header that the chemical feed lines tie into.

The existing chain wheel operators may be reused.

DRAWINGS

M-301 ENLARGED BOILER ROOM PLAN

Specified valve is correct and should be included in the bid.

End of Addendum No. 2

