



ADDENDUM NO. 3

DATE: September 21, 2018

PROJECT: City of Milan Utility Infrastructure Improvements and Extension

OWNER: City of Milan

BID DATE: Tuesday, September 25, 2018

The following shall be incorporated into the Contract Documents dated **8 August 2018**

This Addendum contains 2 pages.

PROJECT MANUAL

Please see below for clarification on the size and configuration of the transfer switches for the project.

26 36 00 TRANSFER SWITCHES

2.1. F

1. Switch shall have AIC rating of 22 KA Symmetrical.
2. Short-time withstand capability for 10 cycles.

2.1. F. J. This paragraph has been completely omitted.

ACKNOWLEDGEMENT of RECEIPT OF ADDENDUM 3

ATTENTION:

Please complete this form and return immediately by email to Trista.McLaughlin@ohm-advisors.com.

Our firm: _____

has received from Orchard, Hiltz, & McCliment, Inc.

Addendum No. 1 for: **City of Milan Utility Infrastructure Improvements
and Extension**

City of Milan

OHM Job No. 0185-17-0080

Today, _____ (date) at _____ (time) a.m. / p.m. (circle one)

Signature of receiver: _____

Printed name of receiver: _____

Company name: _____

End of Addendum No. 3