

**TWIN VALLEY PUMP STATION IMPROVEMENTS - CITY OF FARMINGTON
FARMINGTON, MI 48335**

**BIDS TO BE RECEIVED UNTIL 1:00 P.M., LOCAL TIME, WEDNESDAY, OCTOBER 28, 2015,
AT THE OFFICE OF THE CITY CLERK LOCATED AT 23600 LIBERTY STREET, FARMINGTON, MI 48335**

**OHM Advisors
34000 Plymouth Road
Livonia, MI 48150**

**ADDENDUM NO. 2
October 27, 2015**

The following changes, additions, and/or clarifications to the Contract Documents shall be incorporated in said documents and shall be allowed for in the unit prices bid by the Contractor such that the unit prices indicated in the Bid Form shall represent the conditions as set forth in the Contract Documents and this addendum. The bidder shall acknowledge the receipt of this addendum on page 00 41 00-1 of the BID FORM section.

The Bidder shall also return, via facsimile or email, the acknowledgment sheet located on page 3 of this addendum.

This Addendum contains 3 pages.

CHANGES TO PRIOR ADDENDA

1. Addendum No. 1, Page 1, Item No. 2, BID FORM – Delete the Bid Form attached to Addendum No.1 and substitute the attached Bid Form Page 00 41 00 – Page 3 of 5Add2.

TABLE OF CONTENTS

2. Table of Contents, Page iii – Delete “40 72 13 ULTRASONIC LEVEL METERS40 72 13_1-4”

CHANGES TO SPECIFICATIONS

3. ALLOWANCES, page 01 21 00-2, SCHEDULE OF ALLOWANCES 3.3.B – In the second line of this paragraph, delete “\$50,000” and substitute “\$95,000”.
4. UNIT PRICES, page 01 22 00-10, SCADA Allowance – In the second line of this paragraph, delete “\$50,000” and substitute “\$95,000”.
5. ULTRASONIC LEVEL METERS, page 40 72 13-1-4 – Delete this section in its entirety.
6. DISTRIBUTED PROCESS CONTROL SYSTEMS, page 40 94 23-1, SUMMARY 1.1.A. – In the eighth line of this paragraph, add the following text after the word “instruments”: “including the wet well pressure transducer and the magnetic flow meter.”

<u>Item No.</u>	<u>Description</u>	<u>Estimated Quantity</u>	<u>Unit</u>	<u>Bid Unit Price</u>	<u>Bid Price</u>
1	Mobilization, Max. 5%	1	LS	\$ _____	\$ _____
2	Traffic Control	1	LS	\$ _____	\$ _____
3	Erosion Sediment Control	1	LS	\$ _____	\$ _____
4	Pulverize Drive	1260	SYD	\$ _____	\$ _____
5	Sidewalk Removal	35	SYD	\$ _____	\$ _____
6	Tree Removal	7	EA	\$ _____	\$ _____
7	Clearing and Grubbing	1	LS	\$ _____	\$ _____
8	Metal Object Removal	1	LS	\$ _____	\$ _____
9	Abandon 4" Force Main with Flowable Fill	160	FT	\$ _____	\$ _____
10	Bulkhead 4" Force Main	3	EA	\$ _____	\$ _____
11	Electrical Demolition	1	LS	\$ _____	\$ _____
12	Station Grading, Access Drive	7	STA	\$ _____	\$ _____
13	Station Grading, Site	1	LS	\$ _____	\$ _____
14	1x3 Crushed Stone	1260	SYD	\$ _____	\$ _____
15	8" Thick Concrete Apron	60	SYD	\$ _____	\$ _____
16	4" Concrete Sidewalk	307	SFT	\$ _____	\$ _____
17	6" Concrete Sidewalk	187	SFT	\$ _____	\$ _____
18	6" IPS DR11 HDPE FM, Directional Drill	147	FT	\$ _____	\$ _____
19	6" IPS DR11 HDPE FM, Open Cut	35	FT	\$ _____	\$ _____
20	12" PVC Sanitary Sewer	55	FT	\$ _____	\$ _____
21	Standard 4' Manhole	1	EA	\$ _____	\$ _____
22	Manhole Bench Repair	2	EA	\$ _____	\$ _____
23	Bypass Pumping	1	LS	\$ _____	\$ _____
24	Topsoil, Seed and Mulch	250	SYD	\$ _____	\$ _____
25	Mulch Blanket	250	SYD	\$ _____	\$ _____
26	Pump Station	1	LS	\$ _____	\$ _____
27	Allowance No. 1 – DTE Allowance	1	LS	\$ 15,000.00	\$ 15,000.00
28	Allowance No. 2 – SCADA Allowance	1	LS	\$ 95,000.00	\$ 95,000.00
Total of all Bid Prices					\$ _____

Unit Prices have been computed in accordance with Paragraph 11.03.B of the General Conditions.

Bidder acknowledges that estimated quantities are not guaranteed, and are solely for the purpose of comparison of Bids, and final payment for all Unit Price Bid items will be based on actual quantities, determined as provided in the Contract Documents.

ACKNOWLEDGEMENT of RECEIPT OF ADDENDUM

ATTENTION:

Please complete this form and return immediately by facsimile to OHM Advisors at 734-522-6427 or by email to jennifer.pringle@ohm-advisors.com.

Our firm: _____

has received from OHM Advisors:

Addendum No. 2 for: **Twin Valley Pump Station Improvements**
 City of Farmington
 OHM Job No. 0111-13-0030

Today, _____ (date) at _____ (time) a.m. / p.m. (circle one)

Signature of receiver: _____

Printed name of receiver: _____

Company name: _____

End of Addendum No. 2